



Phone: 403 243 7740 | Fax: 403 243 7520  
 552 42 Avenue SE, Calgary AB T2G 1Y6  
 www.remismechanical.com

## FIRE HYDRANT TEST REPORT

NAME OF PROJECT:  
 ADDRESS:  
 MUNICIPALITY:

ORDER:  
 TESTED BY: Sean Turner  
 TIME:  
 DATE:

TEST#	# OF OUTLETS	ORIFICE SIZE (mm)	PITOT READING (KPA)	TOTAL FLOW (L/MIN)	RESIDUAL PRESSURE (KPA)	STATIC PRESSURE (KPA)	MAKE	YEAR

Yes=Satisfactory	No=Unsatisfactory	(See Comments)			
		Hydrant is accessible and free of obstructions			
		Top of hydrant is not leaking when hydrant is on			
		Gaskets under caps are not leaking when hydrant is on			
		Hydrant barrel is in good condition without cracks or corrosion			
		Operating nut is not worn and does not have rounded corners			
		Hydrant drains properly (in dry barrel hydrants)			
		Nozzle threads are not damaged			
		Outlet caps secured and not leaking			
		Isolation valve located and works properly			

COMMENTS: